

## 2006 Annual Drinking Water Quality Report

# WINTER HAVEN

## *The Chain of Lakes City*

We're pleased to present to you this year's Annual Quality Water Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water source is thirteen wells that draw water from the Floridian aquifer. This water is aerated to release volatile contaminants, chlorinated for disinfection, then fluoridated for dental purposes and finally orthophosphate is added for inhibiting corrosion and deposition in the distribution

If you have any questions about this report or concerning your water utility, or want to obtain a copy of this report, please contact Steven Warder, Chief Water Plant Operator (863) 291-5767. We want our valued customers to be informed about their water utility.

The City Of Winter Haven routinely monitors for contaminants in your drinking water according to Federal and State laws, rules and regulations. Except where indicated otherwise, this report is based on the results of our monitoring for the period of January 1<sup>st</sup> to December 31<sup>st</sup>, 2006. Also included are test results in earlier years for contaminants sampled less often than annually. For contaminants not required to be tested for in 2006, test results are for the most recent testing done in accordance with regulations authorized by the state and approved by the United States Environmental Protection Agency (EPA).

As water travels over the land or underground it can pick up substances or contaminants such as microbes, inorganic and organic chemicals, and radioactive substances. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some contaminants. It's important to remember that the presence of these contaminants does not necessarily pose a health risk.

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water, which must provide the same protection for public health.

Contaminants that may be present in source water include:

**Microbial contaminants**, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.

**Inorganic contaminants**, such as salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.

**Pesticides and herbicides**, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.

**Organic chemical contaminants**, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can, also come from gas stations, urban storm water runoff, and septic systems.

**Radioactive contaminants**, which can be naturally occurring, or be the result of oil and gas production or mining activities.

In the data table you will find many terms you might not be familiar with. To help you better understand these terms we've provided the following key to these terms' abbreviations and definitions:

TERMS Appearing in TABLE		DEFINITION
Action Level	AL	The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow
Not Applicable	N/A	Does not apply
Not-Detected	ND	Means not detected and indicates that the substance was not found by laboratory analysis.
Parts per million	ppm	One part by weight of analyte to one million parts by weight of the water sample.
Parts per billion	ppb	One part by weight of analyte to one billion parts by weight of the water sample.
Picocuries per liter	pCi/L	- <i>picocuries per liter</i> is a measure of the radioactivity in water
Maximum Contaminant Level	MCL	The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology. <b>Maximum Contaminant Levels (MCL)</b> are set at very stringent levels. To understand the possible health effects described for many regulated constituents, a person would have to drink 2 liters of water every day at the MCL level for a lifetime to have a one-in-a-million chance of having the described health effect.
Maximum Contaminant Level Goal	MCLG	The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

*Maximum residual disinfectant level or MRDL: The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.*

*Maximum residual disinfectant level goal or MRDLG: The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.*

More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791

## TEST TABLE RESULTS

\*\* Results in the Level Detected column for radiological contaminants, inorganic contaminants are the highest average at any of the sampling points or the highest detected level at any sampling point, depending on the sampling frequency.

Contaminant And Unit of Measurement	Dates of Sampling (MO./YR.)	MCL Violation YES/NO	Level Detected **	Range of Results	MCLG	MCL	Likely Source of Contamination
<b>Radiological Contaminants</b>							
Alpha emitters (pCi/l)	1/1/03-12/31/03	N	2.2	ND-2.2	0	15	Erosion of natural deposits
Radium 226/Radium 228 or combined Radium (pCi/l)	1/1/03-12/31/03	N	1.9	1.5 - 1.9	0	5	Erosion of natural deposits
<b>Inorganic Contaminants</b>							
Nitrate (ppm)	01/1/06 – 12/31/06	N	0.39	ND – 0.39	10	10	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
Fluoride (ppm)	1/1/05-12/31/05	N	.88	0.68 To 1.01	4	4	Erosion of natural deposits; water additive which promotes strong teeth when at optimum levels between 0.7 and 1.2 ppm.
Sodium (ppm)	1/1/05-12/31/05	N	19.7	11.1 To 19.7	N/A	160	Salt water intrusion, leaching from soil

### TTHM's and Stage 1 Disinfectant/Disinfection By-Product (D/DBP) Parameters

Contaminant and Unit of Measurement	Dates of Sampling MO/YR	MCL Violation YES / NO	Level Detected	Range of Results	MCLG or MRDLG	MCL or MRDL	Likely Source of Contamination
<b>Chlorine:</b> Level Detected is the 2006 monthly average for residual Chlorine; Range of Results is the range of 2006 monthly Chlorine residual level results (lowest to highest) at the individual sampling sites. <b>TTHMs and HAA5s:</b> Level Detected is the 2006 quarterly (or running annual) average; Range of Results is the range of results (lowest to highest) at the individual sampling sites.							
Chlorine (ppm)	1/1/06-12/31/06	N	2.1	1.6 to 2.4	MRDLG = 4.0	MRDL = 4.0	Water additive used to control microbes

HAA5 (Haloacetic Acid) (ppb)	1/1/06-12/31/06	N	11.77	ND to 47.8	NA	MCL = 60	By-product of drinking water disinfection
TTHM [Total Trihalomethanes] (ppb)	1/1/06-12/31/06	N	60	8.2 to 185	NA	MCL = 80	By-product of drinking water disinfection

Contaminant And Unit of Measurement	Dates of sampling (mo./yr.)	AL Violation YES / NO	90th Percentile Result	No. Of sampling sites exceeding the AL	MCLG	AL (Action Level)	Likely Source of Contamination
<b>Lead and Copper (Tap Water)</b>							
Copper (tap water) (ppm)	1/1/06 – 6/30/06	N	0.76	1	1.3	1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
	7/1/06-12/31/06	N	0.58				
Lead (tap water) (ppb)	1/1/06-6/30/06	N	0.33	0	0	15	Corrosion of household plumbing systems, erosion of natural deposits
	7/1/06-12/31/06	N	0.24				

Infants and young children are typically more vulnerable to lead in drinking water than the general population. It is possible that lead levels at your home may be higher than at other homes in the community as a result of materials used in your home's plumbing. If you are concerned about elevated lead levels in your home's water, you may wish to have your water tested and flush your tap for 30 seconds to 2 minutes before using tap water. Additional information is available from the Safe Drinking Water Hotline (1-800-426-4791).

Lead in drinking water is rarely the sole cause of lead poisoning, but it can add to a person's total lead exposure. All potential sources of lead in the household should be identified and removed, replaced or reduced.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791)

Florida's DEP is in the process of conducting Source Water Assessment (SWA), for all public water systems in Florida, to identify and assess any potential sources of contamination in the vicinity of your water supply.

A 5-year ground water travel time around each well, defined by the area from which water will drain to a well pumping at the average daily permitted rate for a five-year period of time, was used to define the assessment area. A SWA conducted for this system in 2004 found that your system's wells are at risk due to:

Risk Level	Contamination Source	Potential Danger
High	Delineated Area	Area of known ground water contamination
Moderate to High	Petroleum Storage Tanks	Potential to leak VOC hydrocarbon fuels
High	Dry Cleaning Facilities	VOC solvent contaminants
Low	Industrial Wastewater	Agricultural production / processing activities

A SWA report for this system is available at the DEP SWAPP web site: [www.dep.state.fl.us/swapp](http://www.dep.state.fl.us/swapp).

Please call Steven Warder, Chief Water Plant Operator (863) 291-5767 if you have questions.